


## 2022-23 Winter Control Times

Load Description	Control Class / Address	Alert On	Alert Off	Control Start	All Loads Controlled	Restoral Start	All Loads Restored
<b>WINTER AM FULL LOAD CONTROL SCHEDULE</b>							
Interruptible Heat (12hr+ backup)	Class 2 & 2W	n/a	n/a	6:55	6:55	9:55	10:55
Interruptible Heat (4hr+ backup)	Class 4B	n/a	n/a	6:55	6:55	9:55	10:25
<b>WINTER PM FULL LOAD CONTROL SCHEDULE</b>							
Peak Alert Notification Devices	Alert PA, Alert PA-W	15:55	20:05	n/a	n/a	n/a	n/a
Manual Standby Generators	Classes 5B, 5B-W	16:20	20:10	16:50	16:50	20:20	20:20
Dairy Water Heaters	Class 4A	n/a	n/a	16:55	16:55	20:00	20:00
Grain Drying	Class 24	16:45	21:10	16:55	16:55	21:10	21:10
<b>DAILY ENERGY STORAGE SCHEDULE</b>							
Off-peak Storage Mon-Fri	Class 3-MF	n/a	n/a	4:55	5:55	11:25	12:25
		n/a	n/a	14:55	15:55	21:25	22:25
Off-peak Storage 7-day	Class 3-DLY	n/a	n/a	4:55	5:55	11:25	12:25
		n/a	n/a	14:55	15:55	21:25	22:25
Off-peak Large Storage	Class 3-A1	n/a	n/a	7:00	7:30	22:55	23:30
Off-peak Winter Storage - PM only	Class 3-WP	n/a	n/a	14:55	15:55	21:25	22:25
Off-Peak EV Charging	Class 3-EV	n/a	n/a	13:30	14:00	21:00	21:30
<b>ECONOMIC CONTROL SCHEDULE</b>							
Water Heater 4hr (small)	Class 1A	n/a	n/a	17:00			21:00
Water Heater 6hr (large)	Class 1B	n/a	n/a	16:00			22:00
Dairy Water Heaters	Class 4A	n/a	n/a	17:00			22:00
Interruptible Heat (12hr+ backup)	Classes 2 & 2W	n/a	n/a	17:00			21:00
Interruptible Heat (4hr+ backup)	Classes 4B	n/a	n/a	17:00			20:00
<b>LOAD MODIFYING RESOURCE CONTROL SCHEDULE (MAX GEN Capacity Resource)</b>							
Water Heater 4hr (small)	Class 1A	At least 1 hour prior to control period	At end of control period	Load control can occur: - At anytime, at the discretion of MISO - With no less than 2 hour notification - At least once each season, up to 16 times annually		Restoral time will vary based on MISO's needs, but total continuous control duration will not exceed 4.5 hours	
Water Heater 6hr (large)	Class 1B	At least 1 hour prior to control period	At end of control period	Load control can occur: - At anytime, at the discretion of MISO - With no less than 2 hour notification - At least once each season, up to 16 times annually		Restoral time will vary based on MISO's needs, but total continuous control duration will not exceed 6 hours	
Auto Standby Generators	Classes 5A, 5A-W, & AE-1	At least 1 hour prior to control period	At end of control period	Load control can occur: - At anytime, at the discretion of MISO - With no less than 2 hour notification - At least once each season, up to 16 times annually		Restoral time will vary based on MISO's needs, but total continuous control duration will not exceed 4.5 hours	