

## Control Times - Summer 2022

Load Description	Control Class / Alert Class	Program Initiated	Alert On	Alert Off	Control Start	All Loads Controlled	Restoral Start	All Loads Restored
<b>FULL LOAD CONTROL SCHEDULE</b>								
Alert Devices	Alert PA	13:00	13:00	18:00	n/a	n/a	n/a	n/a
Small Water Heaters	Class 1A	13:55	n/a	n/a	14:30	14:30	18:00	19:00
Large Water Heaters	Class 1B	13:55	n/a	n/a	14:00	14:00	19:00	20:00
Dairy Water Heaters	Class 4A	13:55	n/a	n/a	14:00	14:00	18:30	19:00
Air Conditioners <sup>1</sup>	Classes 2, 2S, & 4B	13:45	n/a	n/a	13:45	14:00	18:15	18:30
Grain Drying	Class 24	13:40	13:45	18:05	13:55	13:55	18:05	18:05
C & I Auto Standby Generators	Classes 5A & AE-1	13:40	13:45	18:05	13:55	13:55	18:05	18:05
C & I Manual Standby, Peak Alert	Class 5B	13:20	13:25	18:05	13:55	13:55	18:05	18:05
Irrigation	Class 8	13:00	13:05	18:05	13:55	13:55	18:05	18:05
<b>DAILY ENERGY STORAGE SCHEDULE</b>								
Off-Peak ETS - Weekdays	Class 3-MF	11:30	n/a	n/a	11:30	12:00	20:00	20:30
Off-Peak ETS - All Days	Class 3-DLY	11:30	n/a	n/a	11:30	12:00	20:00	20:30
Off-Peak Large ETS - Weekdays	Class 3-A1	7:00	n/a	n/a	7:00	7:30	23:00	23:30
Off-Peak EV Charging - Weekdays	Class 3-EV	13:30	n/a	n/a	13:30	14:00	21:00	21:30
<b>ECONOMIC CONTROL SCHEDULE</b>								
Small Water Heaters	Class 1A	varied	n/a	n/a	19:00	Economic Control can occur anytime between Start and Restoral times, depending on market prices.		23:00
Large Water Heaters	Class 1B	varied	n/a	n/a	18:00			0:00
Dairy Water Heaters	Class 4A	varied	n/a	n/a	18:00			23:00
Air Conditioners	Classes 2, 2S, & 4B	varied	n/a	n/a	18:00			22:30

**Notes:**

1. Air conditioners cycling occurs randomly over 30 minutes with last air conditioner controlled by 2:15 p.m. Maximum total A/C control (saturation) begins at 2:00 p.m. and ends at 6:15 p.m.